



# City of Escondido Fire Department

1163 N Centre City Parkway  
Escondido, CA 92026

Phone: 760-839-5400 Fax: 760-739-7060



## Guidelines for Recreational Fires and Portable Outdoor Fireplaces

**Natural Gas** or **Propane** fire pits shall not be **within 10 feet of combustible** walls, roofs, other combustible materials or vegetation, including ornamental plant material. **Wood Burning** pits shall be **25 feet from any combustible materials** or vegetation and have a proper **spark arrestor or screen**. Consult the City/County Building Department for correct design features and installation standards.

2013 California Fire Code Section 307.1.1 states open burning shall be prohibited when atmospheric condition or local circumstances make such fire hazardous.

### Natural Gas

20-in Wide - 60,000-BTU  
Stainless Steel Stainless Steel  
Natural Gas Design. **Natural  
Gas is lighter than air.**



### Propane Gas

19.5-in W 40,000-BTU Stone  
Design Composite **Propane  
Gas is heavier than air-  
No pits allowed**



### Wood-Burning Fire Pit

